



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197 Facsimile 813.754.9989

Florida Board of Professional Engineers Certificate of Authorization No. 9813

Product Evaluation Report

Report No.: FL-7960.2 R3
Date: January 5, 2009
Product Category: Exterior Doors
Product sub-category: Swinging Exterior Door Assemblies
Product Name: Flush Glazed Fiberglass Door
Outswing
"Impact"
Manufacturer: Trinity Glass International
4621 192nd Street East
Tacoma, WA 98446
Phone 253.875.7300

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Trinity Glass International based on Rule Chapter No. 9B-72.070, Method 1d of the State of Florida Product Approval, Department of Community Affairs-Florida Building Commission.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code (2007 Edition)

See Drawing No. FL-7960.2 prepared by R W Building Consultants, Inc. and signed and sealed by Lyndon F. Schmidt, P.E. (FL # 43409) for specific use parameters.

Lyndon F. Schmidt, P.E.
FL No. 43409
January 5, 2009

Limitations

1. This product has been evaluated and is in compliance with the 2007 Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in the "HVHZ" this product complies with section 1626 of the 2007 FBC and does not require an impact resistant covering.
4. When used in areas requiring wind borne debris protection this product complies with Section 1609.1.2 of the 2007 FBC and does not need to be protected with an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E1996.
5. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
6. Site conditions that deviate from the details of drawing FL-7960.2 require further engineering analysis by a licensed engineer or registered architect.
7. This product meets water infiltration requirements for "HVHZ".
8. See drawing FL-7960.2 for size and design pressure limitations.



Lyndon F. Schmidt, P.E.
FL No. 43409
January 5, 2009

Supporting Documents

A Drawing

1. Drawing No. FL-7960.2 prepared by R W Building Consultants, Inc. (Florida Board of Professional Engineers Certificate of Authorization No. 9813), signed and sealed by Lyndon F. Schmidt, P.E.

B Tests

1. Materials (Fiberglass Skins) approval number 05-1206.01 issued by Miami-Dade BCCO.
2. Materials (PVB Interlayer by DuPont) approval number 04-0816.02 issued by Miami-Dade BCCO.
3. Materials (Polyurethane Foam) testing per ASTM D1929-96 (2001) as performed by ETC Laboratories and reported in test report ETC 05-781-17122.0, signed by Joseph Labora Doldan, P.E.
4. Materials (Polyurethane Foam) testing per ASTM E84-05 (ASTM E-84-05 is equivalent to ASTM E84-04 referenced in the 2007 FBC as evidenced by Evaluation Report EQ-E84-05-04 prepared, signed and sealed by Lyndon F. Schmidt, P.E.) as performed by ETC Laboratories and reported in test report ETC 05-781-17122.0, signed by Joseph Labora Doldan, P.E.
5. Testing per TAS 201-94, 202-94 & TAS 203-94 as performed by Testing Evaluation Laboratories, Inc. and reported in test report TEL 06-0918-1, signed by Wendell W. Haney, P.E.
6. Testing per TAS 201-94, 202-94 & TAS 203-94 as performed by Testing Evaluation Laboratories, Inc. and reported in test report TEL 08-01370020, signed by Wendell W. Haney, P.E.
7. Testing per TAS 201-94, 202-94 & 203-94 as performed by Testing Evaluation Laboratories, Inc. and reported in test report TEL 01370051, signed by Lyndon F. Schmidt, P.E.
8. Testing per TAS 201-94, 202-94 & 203-94 as performed by Testing Evaluation Laboratories, Inc. and reported in test report TEL 01370079, signed by Lyndon F. Schmidt, P.E.

C Calculations

1. Product anchoring for tested specimens is in accordance with manufacturer's published recommendations as substantiated by tested specimens reported in test report TEL 06-0918-1, TEL 08-01370020, TEL 01370051 and TEL 01370079. Additional product anchor analysis for loading conditions prepared, signed and sealed by Lyndon F. Schmidt, P.E.
2. Buck anchor analysis for loading conditions prepared, signed and sealed by Lyndon F. Schmidt, P.E.
3. Glass load resistance calculations per ASTM E1300 prepared, signed and sealed by Lyndon F. Schmidt, P.E.

D Other

1. Certificate of Participation issued by National Accreditation and Management Institute, certifying that Trinity Glass International is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.



Lyndon F. Schmidt, P.E.
FL No. 43409
January 5, 2009