



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.: FL-37184.6

Date: August 1, 2023

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Trinity Glass International 33615 1st Way S Federal Way, Washington 98446	Opaque Fiberglass Door Double w/ or w/out Sidelite(s) Outswing "Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Trinity Glass International based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in the "HVHZ", this product complies with Section 1626 of the Florida Building Code and does not require an impact resistant covering.
4. When used in areas outside of the "HVHZ" requiring wind borne debris protection, this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This products meets missile level "D" and includes Wind Zone 4 as defined in ASTM E1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
5. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
6. Site conditions that deviate from the details of drawing FL-37184.6 require further engineering analysis by a licensed engineer or registered architect.
7. This product meets the water infiltration requirements for the "HVHZ".
8. See drawing FL-37184.6 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|--|---|---|--|
| 1. Test Report No.
TEL 04253718
TEL 01370206A
TEL 01370206B
TEL 01370206C
TEL 01370206D
TEL 01370210A
TEL 01370210B
TEL 01370210C
TEL 01370210D | Test Standard
TAS 201, 202 & 203-94
ASTM D 1929-96
ASTM D D 635-03
ASTM D 2843-99
ASTM G 155-05a, D 638-03
ASTM D 1929-96
ASTM D D 635-03
ASTM D 2843-99
ASTM G 155-05a, D 638-03 | Testing Laboratory
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc.
Testing Evaluation Lab.,Inc. | Signed by
William B. Shelton, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E. |
| 2. Miami Dade NOA
21-0216.01 | Materials Testing
Saflex Interlayer (Eastman Chemical Company) | | |
| 3. Drawing No.
No. FL 37184.6 | Prepared by
RW Building Consultants, Inc. (#9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 4. Calculations
Anchoring
ASTM E1300 Glass Load | Prepared by
RW Building Consultants, Inc. (#9813)
Lyndon F. Schmidt, P.E. | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 5. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Trinity Glass International is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 8-01-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA